



part of
ALS Limited

Specialists in Drinking Water Testing Technologies ■ Residential ■ Industrial ■ Municipal

York Analytical Laboratory A Division of ALS Limited

2161 WHITESVILLE ROAD TOMS RIVER, NJ 08755 PHONE 732-914-1515 FAX 732-914-1616

NJ Lab Cert. # 15001

CERTIFICATE OF ANALYSIS

Customer : Garden State Environmental
555 South Broad Street, Suite K
Glen Rock, NJ 07452

Project ID : Monmouth Court School (9058), 26 Monmouth Court, Livingston, NJ

PAS Project ID : P25-03359

Matrix : Drinking Water

Report Date : 5/12/2025

PAS Sample ID	Client ID	Analysis	Results	Units	DF	PQL	MDL	MCL	Method	Date Sampled	Date Analyzed
P25-03359-01	LMC-B-WC01A (Basement Hall)	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/17/25 09:46	5/5/25 18:54
P25-03359-02	LMC-B-BF01A (Basement Hall)	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/17/25 09:50	5/5/25 19:12
P25-03359-03	LMC-2-WC02A (Upstairs Hall)	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/17/25 10:13	5/5/25 19:16
P25-03359-04	LMC-2-BF02A (Upstairs Hall)	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/17/25 10:17	5/5/25 19:21
P25-03359-05	LMC-4-17-FBA (Field Blank)	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/17/25 10:18	5/5/25 19:34

Except for the parameters tested, York Analytical makes no representation as to the fitness or quality of the water sample taken.

PQL = Practical Quantitation Limit

MDL = Minimum Detection Limit

MCL = Maximum Contaminant Level

DF = Dilution Factor

ND = Analyzed for but not detected

J = Estimated result

* NJ Dept of Education & Dept of Children & Families Action Level

All samples are analyzed in accordance with
New Jersey Department of Environmental
Protection Protocol

Kelly Hogan - Quality Assurance Officer