

CERTIFICATE OF ANALYSIS

Customer : Garden State Environmental
555 South Broad Street, Suite K
Glen Rock, NJ 07452

Project ID : Riker Hill Elementary School (9058), 31 Blackstone Drive, Livingston, NJ
PAS Project ID : P25-03360

Matrix : Drinking Water
Report Date : 5/12/2025

PAS Sample ID	Client ID	Analysis	Results	Units	DF	PQL	MDL	MCL	Method	Date Sampled	Date Analyzed
P25-03360-01	LRH-1-B01A (Room K-1)	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/17/25 11:17	5/6/25 13:28
P25-03360-02	LRH-1-B02A (Room K-2)	Lead	3.45	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/17/25 11:24	5/6/25 13:46
P25-03360-03	LRH-1-B03A (Room K-3)	Lead	1.18 J	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/17/25 11:27	5/6/25 13:59
P25-03360-04	LRH-1-S01A (Faculty Room)	Lead	1.03 J	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/17/25 11:30	5/6/25 14:03
P25-03360-05	LRH-1-S02A (Nurse Next To BR)	Lead	1.48 J	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/17/25 11:32	5/6/25 14:08
P25-03360-06	LRH-1-S03A (Nurse Next Main Office)	Lead	1.64 J	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/17/25 11:36	5/6/25 14:12
P25-03360-07	LRH-1-S04A (Main Office)	Lead	1.18 J	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/17/25 11:38	5/6/25 14:17
P25-03360-08	LRH-1-WC03A (Hall by Main Office R)	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/17/25 11:40	5/6/25 14:21
P25-03360-09	LRH-1-BF01A (Hall by Main Office R)	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/17/25 11:43	5/6/25 14:26
P25-03360-10	LRH-1-WC04A (Hall by Main Office L)	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/17/25 11:44	5/6/25 14:30
P25-03360-11	LRH-1-S06A (Kitchen 3 Comp)	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/17/25 11:49	5/6/25 14:35
P25-03360-12	LRH-1-H01A (Kitchen 3 Comp)	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/17/25 11:52	5/6/25 14:48
P25-03360-13	LRH-1-S07A (Kitchen 1 Comp)	Lead	3.45	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/17/25 11:53	5/6/25 14:53
P25-03360-14	LRH-1-B05A (Room 15)	Lead	6.94	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/17/25 11:57	5/6/25 14:57
P25-03360-15	LRH-1-B06A (Room 17)	Lead	1.33 J	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/17/25 12:00	5/6/25 15:02
P25-03360-16	LRH-1-B08A (Room 18)	Lead	6.18	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/17/25 12:02	5/6/25 15:06
P25-03360-17	LRH-1-B07A (Room 16)	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/17/25 12:04	5/6/25 15:11
P25-03360-18	LRH-1-B09A (Room 19)	Lead	1.18 J	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/17/25 12:07	5/6/25 15:16
P25-03360-19	LRH-1-B10A (Room 21)	Lead	1.94 J	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/17/25 12:09	5/6/25 15:20
P25-03360-20	LRH-1-B11A (Room 20)	Lead	1.79 J	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/17/25 12:11	5/6/25 15:25
P25-03360-21	LRH-1-B12A (Room 22)	Lead	7.39	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/17/25 12:14	5/6/25 15:38
P25-03360-22	LRH-1-B13A (Room 23)	Lead	1.64 J	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/17/25 12:16	5/6/25 15:56
P25-03360-23	LRH-1-WC05A (Hall Outside 12R)	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/17/25 12:20	5/6/25 16:00
P25-03360-24	LRH-1-BF02A (Hall Outside 12R)	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/17/25 12:22	5/6/25 16:05
P25-03360-25	LRH-1-WC06A (Hall Outside 12L)	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/17/25 12:25	5/6/25 16:09
P25-03360-26	LRH-1-B14A (Room 12)	Lead	1.33 J	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/17/25 12:28	5/6/25 16:13
P25-03360-27	LRH-1-B15A (Room 11)	Lead	3.15	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/17/25 12:30	5/6/25 16:31
P25-03360-28	LRH-1-B16A (Room 9)	Lead	1.33 J	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/17/25 12:32	5/6/25 16:36
P25-03360-29	LRH-1-B17A (Room 7)	Lead	1.79 J	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/17/25 12:35	5/6/25 16:40
P25-03360-30	LRH-1-B18A (Room 5)	Lead	1.33 J	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/17/25 12:38	5/6/25 16:44
P25-03360-31	LRH-1-B19A (Room 6)	Lead	1.64 J	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/17/25 12:41	5/6/25 16:49
P25-03360-32	LRH-1-B20A (Room 4)	Lead	1.03 J	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/17/25 12:44	5/6/25 16:53
P25-03360-33	LRH-1-B21A (Room 3)	Lead	1.18 J	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/17/25 12:47	5/6/25 16:58
P25-03360-34	LRH-1-B22A (Room 1)	Lead	11.9	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/17/25 12:51	5/6/25 17:02
P25-03360-35	LRH-1-B23A (Room 2)	Lead	7.55	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/17/25 12:54	5/6/25 17:22
P25-03360-36	LRH-1-WC02A (Hall by Room 24R)	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/17/25 12:57	5/6/25 17:27
P25-03360-37	LRH-1-WC01A (Hall by Room 24L)	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/17/25 12:59	5/6/25 17:31
P25-03360-38	LRH-1-BF03A (Hall by Room 24L)	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/17/25 13:02	5/6/25 17:35
P25-03360-39	LRH-1-B28A (Room 30)	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/17/25 13:05	5/6/25 17:40
P25-03360-40	LRH-1-B29A (Room 31)	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/17/25 13:08	5/6/25 17:44
P25-03360-41	LRH-4-17-FBA (Field Blank)	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/17/25 13:09	5/6/25 18:11

Except for the parameters tested, York Analytical makes no representation as to the fitness or quality of the water sample taken.

PQL = Practical Quantitation Limit
MDL = Minimum Detection Limit
MCL = Maximum Contaminant Level
DF = Dilution Factor
ND = Analyzed for but not detected
J = Estimated result
* NJ Dept of Education & Dept of Children & Families Action Level

All samples are analyzed in accordance with
New Jersey Department of Environmental
Protection Protocol



Kelly Hogan - Quality Assurance Officer