



part of
ALS Limited

Specialists in Drinking Water Testing Technologies ■ Residential ■ Industrial ■ Municipal

York Analytical Laboratory A Division of ALS Limited

2161 WHITESVILLE ROAD TOMS RIVER, NJ 08755 PHONE 732-914-1515 FAX 732-914-1616

NJ Lab Cert. # 15001

CERTIFICATE OF ANALYSIS

Customer : Garden State Environmental
555 South Broad Street, Suite K
Glen Rock, NJ 07452

Project ID : Fitness & Wellness Center (9058), 2 Madonna Drive, Livingston, NJ

PAS Project ID : P25-03361

Matrix : Drinking Water

Report Date : 5/12/2025

PAS Sample ID	Client ID	Analysis	Results	Units	DF	PQL	MDL	MCL	Method	Date Sampled	Date Analyzed
P25-03361-01	LHS-1-S19A (Concession Kitchen L)	Lead	1.37 J	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/18/25 09:28	5/5/25 12:27
P25-03361-02	LHS-1-S20A (Concession Kitchen R)	Lead	2.06	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/18/25 09:29	5/5/25 12:31
P25-03361-03	LHS-1-IM04A (Concession Stand)	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/18/25 09:31	5/5/25 12:43
P25-03361-04	LHS-1-WC23A (Boys Team Room L)	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/18/25 09:40	5/5/25 12:59
P25-03361-05	LHS-1-WC24A (Boys Team Room M)	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/18/25 09:42	5/5/25 13:03
P25-03361-06	LHS-1-WC25A (Boys Team Room R)	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/18/25 09:44	5/5/25 13:07
P25-03361-07	LHS-1-WC26A (Girls Team Room L)	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/18/25 09:50	5/5/25 13:11
P25-03361-08	LHS-1-WC27A (Girls Team Room M)	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/18/25 09:52	5/5/25 13:15
P25-03361-09	LHS-1-WC28A (Girls Team Room R)	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/18/25 09:55	5/5/25 13:27
P25-03361-10	LHS-1-WC29A (Center of Hall L)	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/18/25 10:01	5/5/25 13:31
P25-03361-11	LHS-1-WC30A (Center of Hall R)	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/18/25 10:10	5/5/25 13:35
P25-03361-12	LHS-1-BF02A (Center of Hall R)	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/18/25 10:13	5/5/25 13:39
P25-03361-13	LHS-1-WC31A (End of Hall L)	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/18/25 10:16	5/5/25 13:58
P25-03361-14	LHS-1-WC32A (End of Hall R)	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/18/25 10:22	5/5/25 14:02
P25-03361-15	LHS-1-BF01A (End of Hall L)	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/18/25 10:24	5/5/25 14:06
P25-03361-16	LHS-2-WC33A (Wrestling Room)	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/18/25 10:30	5/5/25 14:10
P25-03361-17	LHS-2-WC34A (Weight Room)	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/18/25 10:34	5/5/25 14:14
P25-03361-18	LHS-4-18-FBA (Field Blank)	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/18/25 10:35	5/5/25 14:18

Except for the parameters tested, York Analytical makes no representation as to the fitness or quality of the water sample taken.

PQL = Practical Quantitation Limit

MDL = Minimum Detection Limit

MCL = Maximum Contaminant Level

DF = Dilution Factor

ND = Analyzed for but not detected

J = Estimated result

* NJ Dept of Education & Dept of Children & Families Action Level

All samples are analyzed in accordance with
New Jersey Department of Environmental
Protection Protocol

Kelly Hogan - Quality Assurance Officer