

### Lead Results for Livingston High School

Client : Garden State Environmental  
 Project ID : Livingston BOE #6427, Livingston High School

Field ID	Flushed (Y/N)	Lab. Sample ID	Lab. Name	Lab. ID	Date Sampled	Time Sampled	Analytical Method	Date of Analysis	Time of Analysis	Conc. (ug/L)	Rpt. Limit (ug/L)	DF	Digested (Y/N)	Qfr.
LHS-1-SP-01A	N	P17-1859-01	PAS	NJDEP 15001	4/14/2017	8:24	SM 3113 B	4/27/2017	10:39	4.27	2.00	1	N	
LHS-1-S-02A	N	P17-1859-02	PAS	NJDEP 15001	4/14/2017	8:26	SM 3113 B	4/27/2017	10:46	9.47	2.00	1	N	
LHS-1-S-03A	N	P17-1859-03	PAS	NJDEP 15001	4/14/2017	8:27	SM 3113 B	4/27/2017	11:11	4.02	2.00	1	N	
LHS-1-S-04A	N	P17-1859-04	PAS	NJDEP 15001	4/14/2017	8:24	SM 3113 B	4/27/2017	11:14	5.26	2.00	1	N	
LHS-1-S-05A	N	P17-1859-05	PAS	NJDEP 15001	4/14/2017	8:29	SM 3113 B	4/27/2017	11:18	3.52	2.00	1	N	
LHS-1-S-06A	N	P17-1859-06	PAS	NJDEP 15001	4/14/2017	8:31	SM 3113 B	4/27/2017	11:22	10.2	2.00	1	N	
LHS-1-S-07A	N	P17-1859-07	PAS	NJDEP 15001	4/14/2017	8:32	SM 3113 B	4/27/2017	11:56	<b>33.7</b>	10.0	5	N	
LHS-1-S-08A	N	P17-1859-08	PAS	NJDEP 15001	4/14/2017	8:33	SM 3113 B	4/27/2017	11:33	1.29	2.00	1	N	J
LHS-1-1M-01A	N	P17-1859-09	PAS	NJDEP 15001	4/14/2017	8:35	SM 3113 B	4/27/2017	11:37	-0.19	2.00	1	N	ND
LHS-1-WC-01A	N	P17-1859-10	PAS	NJDEP 15001	4/14/2017	8:42	SM 3113 B	4/27/2017	12:00	-0.19	2.00	1	N	ND
LHS-1-WC-02A	N	P17-1859-11	PAS	NJDEP 15001	4/14/2017	8:42	SM 3113 B	4/27/2017	12:03	-0.19	2.00	1	N	ND
LHS-1-BF-05A	N	P17-1859-12	PAS	NJDEP 15001	4/14/2017	8:42	SM 3113 B	4/27/2017	12:07	-0.19	2.00	1	N	ND
LHS-1-S-09A	N	P17-1859-13	PAS	NJDEP 15001	4/14/2017	8:43	SM 3113 B	4/27/2017	12:11	1.05	2.00	1	N	J
LHS-1-S-10A	N	P17-1859-14	PAS	NJDEP 15001	4/14/2017	8:44	SM 3113 B	4/27/2017	12:15	1.29	2.00	1	N	J
LHS-1-WC-03A	N	P17-1859-15	PAS	NJDEP 15001	4/14/2017	8:48	SM 3113 B	4/27/2017	12:19	-0.19	2.00	1	N	ND
LHS-1-BF-01A	N	P17-1859-16	PAS	NJDEP 15001	4/14/2017	8:48	SM 3113 B	4/27/2017	12:23	-0.19	2.00	1	N	ND
LHS-1-WC-04A	N	P17-1859-17	PAS	NJDEP 15001	4/14/2017	8:48	SM 3113 B	4/27/2017	12:27	0.0557	2.00	1	N	ND
LHS-1-S-11A	N	P17-1859-18	PAS	NJDEP 15001	4/14/2017	8:50	SM 3113 B	4/27/2017	12:38	1.79	2.00	1	N	J
LHS-1-S-14A	N	P17-1859-19	PAS	NJDEP 15001	4/14/2017	8:51	SM 3113 B	4/27/2017	12:42	1.05	2.00	1	N	J
LHS-1-S-12A	N	P17-1859-20	PAS	NJDEP 15001	4/14/2017	8:52	SM 3113 B	4/27/2017	12:46	1.05	2.00	1	N	J
LHS-1-S-13A	N	P17-1859-21	PAS	NJDEP 15001	4/14/2017	8:53	SM 3113 B	4/27/2017	11:54	1.13	2.00	1	N	J
LHS-1-S-15A	N	P17-1859-22	PAS	NJDEP 15001	4/14/2017	8:54	SM 3113 B	4/27/2017	12:02	1.40	2.00	1	N	J
LHS-1-WC-05A	N	P17-1859-23	PAS	NJDEP 15001	4/14/2017	8:59	SM 3113 B	4/27/2017	12:18	1.40	2.00	1	N	J
LHS-1-WC-06A	N	P17-1859-24	PAS	NJDEP 15001	4/14/2017	8:59	SM 3113 B	4/27/2017	12:22	1.40	2.00	1	N	J
LHS-1-WC-07A	N	P17-1859-25	PAS	NJDEP 15001	4/14/2017	9:02	SM 3113 B	4/27/2017	12:34	1.68	2.00	1	N	J
LHS-1-WC-08A	N	P17-1859-26	PAS	NJDEP 15001	4/14/2017	9:03	SM 3113 B	4/27/2017	12:38	1.68	2.00	1	N	J
LHS-1-B-06A	N	P17-1859-27	PAS	NJDEP 15001	4/14/2017	9:06	SM 3113 B	4/27/2017	12:42	1.68	2.00	1	N	J
LHS-1-B-07A	N	P17-1859-28	PAS	NJDEP 15001	4/14/2017	9:07	SM 3113 B	4/27/2017	12:45	2.79	2.00	1	N	
LHS-1-WC-50A	N	P17-1859-29	PAS	NJDEP 15001	4/14/2017	9:11	SM 3113 B	4/27/2017	12:49	0.298	2.00	1	N	ND
LHS-1-WC-51A	N	P17-1859-30	PAS	NJDEP 15001	4/14/2017	9:11	SM 3113 B	4/27/2017	12:53	0.574	2.00	1	N	J
LHS-1-BF-10A	N	P17-1859-31	PAS	NJDEP 15001	4/14/2017	9:12	SM 3113 B	4/27/2017	12:57	0.851	2.00	1	N	J

### Lead Results for Livingston High School

Client : Garden State Environmental  
 Project ID : Livingston BOE #6427, Livingston High School

Field ID	Flushed (Y/N)	Lab. Sample ID	Lab. Name	Lab. ID	Date Sampled	Time Sampled	Analytical Method	Date of Analysis	Time of Analysis	Conc. (ug/L)	Rpt. Limit (ug/L)	DF	Digested (Y/N)	Qfr.
LHS-1-WC-09A	N	P17-1859-32	PAS	NJDEP 15001	4/14/2017	9:16	SM 3113 B	4/27/2017	13:01	0.851	2.00	1	N	J
LHS-1-BF-02A	N	P17-1859-33	PAS	NJDEP 15001	4/14/2017	9:17	SM 3113 B	4/27/2017	13:05	0.851	2.00	1	N	J
LHS-1-WC-10A	N	P17-1859-34	PAS	NJDEP 15001	4/14/2017	9:17	SM 3113 B	4/27/2017	13:10	0.298	2.00	1	N	ND
LHS-1-S-16A	N	P17-1859-35	PAS	NJDEP 15001	4/14/2017	9:19	SM 3113 B	4/27/2017	13:32	1.13	2.00	1	N	J
LHS-1-WC-11A	N	P17-1859-36	PAS	NJDEP 15001	4/14/2017	9:24	SM 3113 B	4/27/2017	13:36	-0.53	2.00	1	N	ND
LHS-1-BF-03A	N	P17-1859-37	PAS	NJDEP 15001	4/14/2017	9:24	SM 3113 B	4/27/2017	14:19	-0.81	2.00	1	N	ND
LHS-1-WC-12A	N	P17-1859-38	PAS	NJDEP 15001	4/14/2017	9:24	SM 3113 B	4/27/2017	14:23	0.0208	2.00	1	N	ND
LHS-1-B-01A	N	P17-1859-39	PAS	NJDEP 15001	4/14/2017	9:26	SM 3113 B	4/27/2017	14:27	0.0208	2.00	1	N	ND
LHS-1-S-18A	N	P17-1859-40	PAS	NJDEP 15001	4/14/2017	9:32	SM 3113 B	4/27/2017	14:31	1.40	2.00	1	N	J
LHS-1-1M-02A	N	P17-1859-41	PAS	NJDEP 15001	4/14/2017	9:35	SM 3113 B	4/27/2017	11:37	-0.30	2.00	1	N	ND
LHS-1-WC-17A	N	P17-1859-42	PAS	NJDEP 15001	4/14/2017	9:37	SM 3113 B	4/27/2017	11:45	0.0741	2.00	1	N	ND
LHS-1-WC-19A	N	P17-1859-43	PAS	NJDEP 15001	4/14/2017	9:38	SM 3113 B	4/27/2017	11:57	-0.30	2.00	1	N	ND
LHS-2-WC-20A	N	P17-1859-44	PAS	NJDEP 15001	4/14/2017	9:47	SM 3113 B	4/27/2017	12:09	-0.30	2.00	1	N	ND
LHS-2-WC-21A	N	P17-1859-45	PAS	NJDEP 15001	4/14/2017	9:47	SM 3113 B	4/27/2017	12:13	-0.30	2.00	1	N	ND
LHS-2-WC-22A	N	P17-1859-46	PAS	NJDEP 15001	4/14/2017	9:47	SM 3113 B	4/27/2017	12:16	-0.30	2.00	1	N	ND
LHS-2-1M-03A	N	P17-1859-47	PAS	NJDEP 15001	4/14/2017	9:49	SM 3113 B	4/27/2017	12:20	-0.67	2.00	1	N	ND
LHS-2-B-04A	N	P17-1859-48	PAS	NJDEP 15001	4/14/2017	9:54	SM 3113 B	4/27/2017	12:24	1.19	2.00	1	N	J
LHS-2-B-05A	N	P17-1859-49	PAS	NJDEP 15001	4/14/2017	9:55	SM 3113 B	4/27/2017	12:28	1.19	2.00	1	N	J
LHS-2-B-03A	N	P17-1859-50	PAS	NJDEP 15001	4/14/2017	9:56	SM 3113 B	4/27/2017	12:32	6.00	2.00	1	N	
LHS-2-S-17A	N	P17-1859-51	PAS	NJDEP 15001	4/14/2017	10:01	SM 3113 B	4/27/2017	12:36	1.56	2.00	1	N	J
LHS-2-H-01A	N	P17-1859-52	PAS	NJDEP 15001	4/14/2017	10:02	SM 3113 B	4/27/2017	12:40	7.85	2.00	1	N	
LHS-2-S-21A	N	P17-1859-53	PAS	NJDEP 15001	4/14/2017	10:05	SM 3113 B	4/27/2017	13:00	3.78	2.00	1	N	
LHS-2-WC-15A	N	P17-1859-54	PAS	NJDEP 15001	4/14/2017	10:09	SM 3113 B	4/27/2017	13:04	-0.67	2.00	1	N	ND
LHS-2-WC-16A	N	P17-1859-55	PAS	NJDEP 15001	4/14/2017	10:09	SM 3113 B	4/27/2017	13:08	-0.67	2.00	1	N	ND
LHS-2-BF-05A	N	P17-1859-56	PAS	NJDEP 15001	4/14/2017	10:09	SM 3113 B	4/27/2017	13:12	-0.67	2.00	1	N	ND
LHS-2-WC-35A	N	P17-1859-57	PAS	NJDEP 15001	4/14/2017	10:13	SM 3113 B	4/27/2017	13:17	-0.67	2.00	1	N	ND
LHS-2-BF-06A	N	P17-1859-58	PAS	NJDEP 15001	4/14/2017	10:13	SM 3113 B	4/27/2017	13:21	-0.67	2.00	1	N	ND
LHS-2-WC-36A	N	P17-1859-59	PAS	NJDEP 15001	4/14/2017	10:13	SM 3113 B	4/27/2017	13:25	-0.67	2.00	1	N	ND
LHS-2-WC-37A	N	P17-1859-60	PAS	NJDEP 15001	4/14/2017	10:16	SM 3113 B	4/27/2017	13:29	-0.67	2.00	1	N	ND
LHS-2-WC-38A	N	P17-1859-61	PAS	NJDEP 15001	4/14/2017	10:17	SM 3113 B	4/27/2017	10:37	0.00	2.00	1	N	ND
LHS-2-BF-07A	N	P17-1859-62	PAS	NJDEP 15001	4/14/2017	10:17	SM 3113 B	4/27/2017	10:45	-0.24	2.00	1	N	ND
LHS-2-WC-13A	N	P17-1859-63	PAS	NJDEP 15001	4/14/2017	10:20	SM 3113 B	4/27/2017	10:56	-0.24	2.00	1	N	ND

### Lead Results for Livingston High School

Client : Garden State Environmental  
 Project ID : Livingston BOE #6427, Livingston High School

Field ID	Flushed (Y/N)	Lab. Sample ID	Lab. Name	Lab. ID	Date Sampled	Time Sampled	Analytical Method	Date of Analysis	Time of Analysis	Conc. (ug/L)	Rpt. Limit (ug/L)	DF	Digested (Y/N)	Qfr.
LHS-2-BF-04A	N	P17-1859-64	PAS	NJDEP 15001	4/14/2017	10:20	SM 3113 B	4/27/2017	11:16	-0.24	2.00	1	N	ND
LHS-2-WC-14A	N	P17-1859-65	PAS	NJDEP 15001	4/14/2017	10:20	SM 3113 B	4/27/2017	11:20	0.00	2.00	1	N	ND
LHS-1-WC-31A	N	P17-1859-66	PAS	NJDEP 15001	4/14/2017	10:31	SM 3113 B	4/27/2017	11:24	0.00	2.00	1	N	ND
LHS-1-WC-32A	N	P17-1859-67	PAS	NJDEP 15001	4/14/2017	10:31	SM 3113 B	4/27/2017	11:28	0.00	2.00	1	N	ND
LHS-1-WC-29A	N	P17-1859-68	PAS	NJDEP 15001	4/14/2017	10:34	SM 3113 B	4/27/2017	11:32	0.00	2.00	1	N	ND
LHS-1-WC-30A	N	P17-1859-69	PAS	NJDEP 15001	4/14/2017	10:34	SM 3113 B	4/27/2017	11:36	0.00	2.00	1	N	ND
LHS-1-WC-28A	N	P17-1859-70	PAS	NJDEP 15001	4/14/2017	10:38	SM 3113 B	4/27/2017	11:40	0.00	2.00	1	N	ND
LHS-1-WC-27A	N	P17-1859-71	PAS	NJDEP 15001	4/14/2017	10:38	SM 3113 B	4/27/2017	11:44	0.00	2.00	1	N	ND
LHS-1-WC-26A	N	P17-1859-72	PAS	NJDEP 15001	4/14/2017	10:38	SM 3113 B	4/27/2017	11:48	0.00	2.00	1	N	ND
LHS-1-WC-23A	N	P17-1859-73	PAS	NJDEP 15001	4/14/2017	10:42	SM 3113 B	4/27/2017	12:00	0.00	2.00	1	N	ND
LHS-1-WC-24A	N	P17-1859-74	PAS	NJDEP 15001	4/14/2017	10:42	SM 3113 B	4/27/2017	12:04	-0.24	2.00	1	N	ND
LHS-1-WC-25A	N	P17-1859-75	PAS	NJDEP 15001	4/14/2017	10:42	SM 3113 B	4/27/2017	12:08	0.00	2.00	1	N	ND
LHS-1-S-19A	N	P17-1859-76	PAS	NJDEP 15001	4/14/2017	10:46	SM 3113 B	4/27/2017	12:12	9.67	2.00	1	N	
LHS-1-S-20A	N	P17-1859-77	PAS	NJDEP 15001	4/14/2017	10:46	SM 3113 B	4/27/2017	12:16	3.87	2.00	1	N	
LHS-1-IM-04A	N	P17-1859-78	PAS	NJDEP 15001	4/14/2017	10:47	SM 3113 B	4/27/2017	12:21	1.94	2.00	1	N	J
LHS-2-WC-33A	N	P17-1859-79	PAS	NJDEP 15001	4/14/2017	10:53	SM 3113 B	4/27/2017	12:25	0.00	2.00	1	N	ND
LHS-2-WC-34A	N	P17-1859-80	PAS	NJDEP 15001	4/14/2017	10:51	SM 3113 B	4/27/2017	12:29	0.00	2.00	1	N	ND
LHS-4-14-FBA	N	P17-1859-81	PAS	NJDEP 15001	4/14/2017	12:17	SM 3113 B	4/27/2017	12:33	0.00	2.00	1	N	ND