

### Lead Results for Heritage Middle School

Client : Garden State Environmental  
 Project ID : Livingston BOE #6427, Heritage

Field ID	Flushed (Y/N)	Lab. Sample ID	Lab. Name	Lab. ID	Date Sampled	Time Sampled	Analytical Method	Date of Analysis	Time of Analysis	Conc. (ug/L)	Rpt. Limit (ug/L)	DF	Digested (Y/N)	Qfr.
LHER-B-S-01A	N	P17-1740-01	PAS	NJDEP 15001	4/11/2017	6:13	SM 3113 B	4/20/2017	15:43	3.82	2.00	1	N	
LHER-B-B-01A	N	P17-1740-02	PAS	NJDEP 15001	4/11/2017	6:22	SM 3113 B	4/20/2017	15:50	1.53	2.00	1	N	J
LHER-B-B-06A	N	P17-1740-03	PAS	NJDEP 15001	4/11/2017	6:25	SM 3113 B	4/20/2017	16:02	1.28	2.00	1	N	J
LHER-B-B-04A	N	P17-1740-04	PAS	NJDEP 15001	4/11/2017	6:28	SM 3113 B	4/20/2017	16:14	1.53	2.00	1	N	J
LHER-B-B-05A	N	P17-1740-05	PAS	NJDEP 15001	4/11/2017	6:31	SM 3113 B	4/20/2017	16:18	0.514	2.00	1	N	J
LHER-B-B-07A	N	P17-1740-06	PAS	NJDEP 15001	4/11/2017	6:36	SM 3113 B	4/20/2017	16:22	-0.25	2.00	1	N	ND
LHER-B-B-08A	N	P17-1740-07	PAS	NJDEP 15001	4/11/2017	6:37	SM 3113 B	4/20/2017	16:26	-0.25	2.00	1	N	ND
LHER-1-B-09A	N	P17-1740-08	PAS	NJDEP 15001	4/11/2017	6:44	SM 3113 B	4/20/2017	16:30	0.514	2.00	1	N	J
LHER-1-B-10A	N	P17-1740-09	PAS	NJDEP 15001	4/11/2017	6:47	SM 3113 B	4/20/2017	16:34	0.006	2.00	1	N	ND
LHER-1-S-02A	N	P17-1740-10	PAS	NJDEP 15001	4/11/2017	6:50	SM 3113 B	4/20/2017	16:39	0.260	2.00	1	N	ND
LHER-1-S-03A	N	P17-1740-11	PAS	NJDEP 15001	4/11/2017	6:52	SM 3113 B	4/20/2017	16:43	0.514	2.00	1	N	J
LHER-1-S-04A	N	P17-1740-12	PAS	NJDEP 15001	4/11/2017	6:53	SM 3113 B	4/20/2017	16:47	0.006	2.00	1	N	ND
LHER-1-S-05A	N	P17-1740-13	PAS	NJDEP 15001	4/11/2017	6:54	SM 3113 B	4/20/2017	16:59	0.260	2.00	1	N	ND
LHER-1-S-06A	N	P17-1740-14	PAS	NJDEP 15001	4/11/2017	6:55	SM 3113 B	4/20/2017	17:03	0.006	2.00	1	N	ND
LHER-1-B-11A	N	P17-1740-15	PAS	NJDEP 15001	4/11/2017	6:59	SM 3113 B	4/20/2017	17:07	0.514	2.00	1	N	J
LHER-1-B-12A	N	P17-1740-16	PAS	NJDEP 15001	4/11/2017	7:03	SM 3113 B	4/20/2017	17:11	1.78	2.00	1	N	J
LHER-1-S-07A	N	P17-1740-17	PAS	NJDEP 15001	4/11/2017	7:03	SM 3113 B	4/20/2017	17:15	0.514	2.00	1	N	J
LHER-1-IM-01A	N	P17-1740-18	PAS	NJDEP 15001	4/11/2017	7:06	SM 3113 B	4/20/2017	17:20	-0.50	2.00	1	N	ND
LHER-1-S-08A	N	P17-1740-19	PAS	NJDEP 15001	4/11/2017	7:10	SM 3113 B	4/20/2017	17:24	0.768	2.00	1	N	J
LHER-1-S-09A	N	P17-1740-20	PAS	NJDEP 15001	4/11/2017	7:11	SM 3113 B	4/20/2017	17:28	1.28	2.00	1	N	J
LHER-1-S-10A	N	P17-1740-21	PAS	NJDEP 15001	4/11/2017	7:12	SM 3113 B	4/20/2017	15:39	1.69	2.00	1	N	J
LHER-1-S-11A	N	P17-1740-22	PAS	NJDEP 15001	4/11/2017	7:13	SM 3113 B	4/20/2017	15:43	2.94	2.00	1	N	
LHER-1-B-13A	N	P17-1740-23	PAS	NJDEP 15001	4/11/2017	7:18	SM 3113 B	4/20/2017	15:47	0.438	2.00	1	N	J
LHER-1-S-14A	N	P17-1740-24	PAS	NJDEP 15001	4/11/2017	7:22	SM 3113 B	4/20/2017	15:52	3.25	2.00	1	N	
LHER-1-S-12A	N	P17-1740-25	PAS	NJDEP 15001	4/11/2017	7:25	SM 3113 B	4/20/2017	15:56	10.4	2.00	1	N	
LHER-1-B-14A	N	P17-1740-26	PAS	NJDEP 15001	4/11/2017	7:26	SM 3113 B	4/20/2017	16:09	2.31	2.00	1	N	
LHER-1-B-17A	N	P17-1740-27	PAS	NJDEP 15001	4/11/2017	7:33	SM 3113 B	4/20/2017	16:13	3.88	2.00	1	N	
LHER-1-S-13A	N	P17-1740-28	PAS	NJDEP 15001	4/11/2017	7:36	SM 3113 B	4/20/2017	16:18	4.19	2.00	1	N	
LHER-2-WC-02A	N	P17-1740-29	PAS	NJDEP 15001	4/11/2017	7:43	SM 3113 B	4/20/2017	16:22	0.438	2.00	1	N	J
LHER-2-B-15A	N	P17-1740-30	PAS	NJDEP 15001	4/11/2017	7:45	SM 3113 B	4/20/2017	16:27	0.125	2.00	1	N	ND
LHER-2-B-16A	N	P17-1740-31	PAS	NJDEP 15001	4/11/2017	7:45	SM 3113 B	4/20/2017	16:31	0.125	2.00	1	N	ND

### Lead Results for Heritage Middle School

Client : Garden State Environmental  
 Project ID : Livingston BOE #6427, Heritage

Field ID	Flushed (Y/N)	Lab. Sample ID	Lab. Name	Lab. ID	Date Sampled	Time Sampled	Analytical Method	Date of Analysis	Time of Analysis	Conc. (ug/L)	Rpt. Limit (ug/L)	DF	Digested (Y/N)	Qfr.
LHER-4-11-FBA	N	P17-1740-32	PAS	NJDEP 15001	4/11/2017	7:51	SM 3113 B	4/20/2017	16:35	0.125	2.00	1	N	ND
LHER-O-SP-01A	N	P17-1740-33	PAS	NJDEP 15001	4/11/2017	8:13	SM 3113 B	4/20/2017	15:22	<b>23.0</b>	8.00	4	Y	