

### Lead Results for Collins Elementary School

Client : Garden State Environmental  
 Project ID : Livingston BOE #6427, Collins ES

Field ID	Flushed (Y/N)	Lab. Sample ID	Lab. Name	Lab. ID	Date Sampled	Time Sampled	Analytical Method	Date of Analysis	Time of Analysis	Conc. (ug/L)	Rpt. Limit (ug/L)	DF	Digested (Y/N)	Qfr.
LCO-1-B-03A	N	P17-1742-01	PAS	NJDEP 15001	4/10/2017	10:20	SM 3113 B	4/21/2017	11:19	1.79	2.00	1	N	J
LCO-1-B-04A	N	P17-1742-02	PAS	NJDEP 15001	4/10/2017	10:24	SM 3113 B	4/21/2017	11:27	1.00	2.00	1	N	J
LCO-1-B-05A	N	P17-1742-03	PAS	NJDEP 15001	4/10/2017	10:26	SM 3113 B	4/21/2017	11:39	0.737	2.00	1	N	J
LCO-1-B-06A	N	P17-1742-04	PAS	NJDEP 15001	4/10/2017	10:29	SM 3113 B	4/21/2017	11:51	2.58	2.00	1	N	
LCO-1-B-07A	N	P17-1742-05	PAS	NJDEP 15001	4/10/2017	10:31	SM 3113 B	4/21/2017	12:47	<b>48.4</b>	10.0	5	N	
LCO-1-B-08A	N	P17-1742-06	PAS	NJDEP 15001	4/10/2017	10:33	SM 3113 B	4/21/2017	12:51	<b>69.5</b>	10.0	5	N	
LCO-1-B-09A	N	P17-1742-07	PAS	NJDEP 15001	4/10/2017	10:35	SM 3113 B	4/21/2017	12:02	4.95	2.00	1	N	
LCO-1-B-10A	N	P17-1742-08	PAS	NJDEP 15001	4/10/2017	10:37	SM 3113 B	4/21/2017	12:06	4.16	2.00	1	N	
LCO-1-S-01A	N	P17-1742-09	PAS	NJDEP 15001	4/10/2017	10:41	SM 3113 B	4/21/2017	12:10	0.211	2.00	1	N	ND
LCO-1-IM-01A	N	P17-1742-10	PAS	NJDEP 15001	4/10/2017	10:42	SM 3113 B	4/21/2017	12:14	-0.58	2.00	1	N	ND
LCO-1-S-02A	N	P17-1742-11	PAS	NJDEP 15001	4/10/2017	10:45	SM 3113 B	4/21/2017	12:18	-0.05	2.00	1	N	ND
LCO-1-S-03A	N	P17-1742-12	PAS	NJDEP 15001	4/10/2017	10:48	SM 3113 B	4/21/2017	12:22	0.211	2.00	1	N	ND
LCO-1-B-13A	N	P17-1742-13	PAS	NJDEP 15001	4/10/2017	10:50	SM 3113 B	4/21/2017	13:07	2.05	2.00	1	N	
LCO-1-B-14A	N	P17-1742-14	PAS	NJDEP 15001	4/10/2017	10:52	SM 3113 B	4/21/2017	13:12	0.211	2.00	1	N	ND
LCO-1-B-15A	N	P17-1742-15	PAS	NJDEP 15001	4/10/2017	10:55	SM 3113 B	4/21/2017	13:16	1.00	2.00	1	N	J
LCO-1-B-16A	N	P17-1742-16	PAS	NJDEP 15001	4/10/2017	10:56	SM 3113 B	4/21/2017	13:50	0.737	2.00	1	N	J
LCO-1-B-17A	N	P17-1742-17	PAS	NJDEP 15001	4/10/2017	10:58	SM 3113 B	4/21/2017	13:54	1.26	2.00	1	N	J
LCO-1-B-18A	N	P17-1742-18	PAS	NJDEP 15001	4/10/2017	11:00	SM 3113 B	4/21/2017	13:59	0.211	2.00	1	N	ND
LCO-1-B-21A	N	P17-1742-19	PAS	NJDEP 15001	4/10/2017	11:05	SM 3113 B	4/21/2017	14:03	-0.05	2.00	1	N	ND
LCO-1-B-22A	N	P17-1742-20	PAS	NJDEP 15001	4/10/2017	11:08	SM 3113 B	4/21/2017	14:07	1.00	2.00	1	N	J
LCO-1-B-23A	N	P17-1742-21	PAS	NJDEP 15001	4/10/2017	11:11	SM 3113 B	4/21/2017	14:11	-0.05	2.00	1	N	ND
LCO-1-B-24A	N	P17-1742-22	PAS	NJDEP 15001	4/10/2017	11:13	SM 3113 B	4/21/2017	14:19	-0.05	2.00	1	N	ND
LCO-1-B-25A	N	P17-1742-23	PAS	NJDEP 15001	4/10/2017	11:14	SM 3113 B	4/21/2017	14:39	0.211	2.00	1	N	ND
LCO-1-B-26A	N	P17-1742-24	PAS	NJDEP 15001	4/10/2017	11:16	SM 3113 B	4/21/2017	14:43	1.79	2.00	1	N	J
LCO-1-B-27A	N	P17-1742-25	PAS	NJDEP 15001	4/10/2017	11:20	SM 3113 B	4/21/2017	14:47	0.211	2.00	1	N	ND
LCO-1-B-28A	N	P17-1742-26	PAS	NJDEP 15001	4/10/2017	11:23	SM 3113 B	4/21/2017	14:51	1.53	2.00	1	N	J
LCO-1-B-29A	N	P17-1742-27	PAS	NJDEP 15001	4/10/2017	11:25	SM 3113 B	4/21/2017	14:55	-0.05	2.00	1	N	ND
LCO-1-B-30A	N	P17-1742-28	PAS	NJDEP 15001	4/10/2017	11:27	SM 3113 B	4/21/2017	14:58	-0.05	2.00	1	N	ND
LCO-1-B-31A	N	P17-1742-29	PAS	NJDEP 15001	4/10/2017	11:29	SM 3113 B	4/21/2017	15:02	0.474	2.00	1	N	J
LCO-4-10-FBA	N	P17-1742-30	PAS	NJDEP 15001	4/10/2017	11:36	SM 3113 B	4/21/2017	15:06	-0.32	2.00	1	N	ND