

### Lead Results for Harrison Elementary School

Client : Garden State Environmental  
 Project ID : Livingston BOE #6427, Harrison

Field ID	Flushed (Y/N)	Lab. Sample ID	Lab. Name	Lab. ID	Date Sampled	Time Sampled	Analytical Method	Date of Analysis	Time of Analysis	Conc. (ug/L)	Rpt. Limit (ug/L)	DF	Digested (Y/N)	Qfr.
LHAR-B-S-01A	N	P17-1739-01	PAS	NJDEP 15001	4/11/2017	8:50	SM 3113 B	4/20/2017	14:48	3.51	2.00	1	N	
LHAR-1-S-02A	N	P17-1739-02	PAS	NJDEP 15001	4/11/2017	8:53	SM 3113 B	4/20/2017	14:52	2.44	2.00	1	N	
LHAR-1-B-01A	N	P17-1739-03	PAS	NJDEP 15001	4/11/2017	8:55	SM 3113 B	4/20/2017	14:56	3.30	2.00	1	N	
LHAR-1-S-03A	N	P17-1739-04	PAS	NJDEP 15001	4/11/2017	8:58	SM 3113 B	4/20/2017	16:52	17.7	4.00	2	N	
LHAR-1-B-02A	N	P17-1739-05	PAS	NJDEP 15001	4/11/2017	9:01	SM 3113 B	4/20/2017	15:12	3.94	2.00	1	N	
LHAR-1-S-04A	N	P17-1739-06	PAS	NJDEP 15001	4/11/2017	9:04	SM 3113 B	4/20/2017	15:16	2.44	2.00	1	N	
LHAR-1-B-03A	N	P17-1739-07	PAS	NJDEP 15001	4/11/2017	9:07	SM 3113 B	4/20/2017	15:20	2.65	2.00	1	N	
LHAR-2-B-04A	N	P17-1739-08	PAS	NJDEP 15001	4/11/2017	9:14	SM 3113 B	4/20/2017	15:24	5.66	2.00	1	N	
LHAR-2-B-05A	N	P17-1739-09	PAS	NJDEP 15001	4/11/2017	9:17	SM 3113 B	4/20/2017	15:28	5.23	2.00	1	N	
LHAR-2-B-06A	N	P17-1739-10	PAS	NJDEP 15001	4/11/2017	9:23	SM 3113 B	4/20/2017	15:32	0.509	2.00	1	N	J
LHAR-2-B-07A	N	P17-1739-11	PAS	NJDEP 15001	4/11/2017	9:26	SM 3113 B	4/20/2017	15:36	6.09	2.00	1	N	
LHAR-2-B-08A	N	P17-1739-12	PAS	NJDEP 15001	4/11/2017	9:27	SM 3113 B	4/20/2017	15:40	2.23	2.00	1	N	
LHAR-1-IM-01A	N	P17-1739-13	PAS	NJDEP 15001	4/11/2017	9:36	SM 3113 B	4/20/2017	15:44	0.0804	2.00	1	Y	ND
LHAR-1-S-05A	N	P17-1739-14	PAS	NJDEP 15001	4/11/2017	9:39	SM 3113 B	4/20/2017	16:09	4.58	2.00	1	N	
LHAR-1-S-06A	N	P17-1739-15	PAS	NJDEP 15001	4/11/2017	9:39	SM 3113 B	4/20/2017	16:13	2.23	2.00	1	N	
LHAR-1-WC-01A	N	P17-1739-16	PAS	NJDEP 15001	4/11/2017	9:42	SM 3113 B	4/20/2017	16:17	1.37	2.00	1	N	J
LHAR-1-B-09A	N	P17-1739-17	PAS	NJDEP 15001	4/11/2017	9:44	SM 3113 B	4/20/2017	16:21	2.87	2.00	1	N	
LHAR-1-B-10A	N	P17-1739-18	PAS	NJDEP 15001	4/11/2017	9:47	SM 3113 B	4/20/2017	16:25	1.58	2.00	1	N	J
LHAR-1-B-11A	N	P17-1739-19	PAS	NJDEP 15001	4/11/2017	9:50	SM 3113 B	4/20/2017	16:29	1.80	2.00	1	N	J
LHAR-1-B-34A	N	P17-1739-20	PAS	NJDEP 15001	4/11/2017	9:53	SM 3113 B	4/20/2017	17:00	4.16	2.00	1	N	
LHAR-1-B-12A	N	P17-1739-21	PAS	NJDEP 15001	4/11/2017	9:55	SM 3113 B	4/20/2017	14:26	4.49	2.00	1	N	
LHAR-1-B-13A	N	P17-1739-22	PAS	NJDEP 15001	4/11/2017	9:59	SM 3113 B	4/20/2017	14:41	1.13	2.00	1	N	J
LHAR-1-B-14A	N	P17-1739-23	PAS	NJDEP 15001	4/11/2017	9:59	SM 3113 B	4/20/2017	14:52	2.53	2.00	1	N	
LHAR-1-B-15A	N	P17-1739-24	PAS	NJDEP 15001	4/11/2017	10:05	SM 3113 B	4/20/2017	14:56	1.13	2.00	1	N	J
LHAR-1-B-16A	N	P17-1739-25	PAS	NJDEP 15001	4/11/2017	10:07	SM 3113 B	4/20/2017	15:00	1.69	2.00	1	N	J
LHAR-1-B-17A	N	P17-1739-26	PAS	NJDEP 15001	4/11/2017	10:12	SM 3113 B	4/20/2017	15:04	2.53	2.00	1	N	
LHAR-1-B-18A	N	P17-1739-27	PAS	NJDEP 15001	4/11/2017	10:15	SM 3113 B	4/20/2017	15:08	1.97	2.00	1	N	J
LHAR-1-B-20A	N	P17-1739-28	PAS	NJDEP 15001	4/11/2017	10:19	SM 3113 B	4/20/2017	15:12	2.53	2.00	1	N	
LHAR-1-B-21A	N	P17-1739-29	PAS	NJDEP 15001	4/11/2017	10:21	SM 3113 B	4/20/2017	15:23	1.97	2.00	1	N	J
LHAR-1-B-22A	N	P17-1739-30	PAS	NJDEP 15001	4/11/2017	10:25	SM 3113 B	4/20/2017	15:27	2.53	2.00	1	N	
LHAR-1-B-23A	N	P17-1739-31	PAS	NJDEP 15001	4/11/2017	10:27	SM 3113 B	4/20/2017	15:31	1.69	2.00	1	N	J

### Lead Results for Harrison Elementary School

Client : Garden State Environmental  
 Project ID : Livingston BOE #6427, Harrison

Field ID	Flushed (Y/N)	Lab. Sample ID	Lab. Name	Lab. ID	Date Sampled	Time Sampled	Analytical Method	Date of Analysis	Time of Analysis	Conc. (ug/L)	Rpt. Limit (ug/L)	DF	Digested (Y/N)	Qfr.
LHAR-1-B-24A	N	P17-1739-32	PAS	NJDEP 15001	4/11/2017	10:30	SM 3113 B	4/20/2017	15:35	2.25	2.00	1	N	
LHAR-1-B-25A	N	P17-1739-33	PAS	NJDEP 15001	4/11/2017	10:33	SM 3113 B	4/20/2017	15:39	1.97	2.00	1	N	J
LHAR-1-B-26A	N	P17-1739-34	PAS	NJDEP 15001	4/11/2017	10:35	SM 3113 B	4/20/2017	15:42	1.13	2.00	1	N	J
LHAR-1-B-27A	N	P17-1739-35	PAS	NJDEP 15001	4/11/2017	10:37	SM 3113 B	4/20/2017	15:46	1.97	2.00	1	N	J
LHAR-1-B-28A	N	P17-1739-36	PAS	NJDEP 15001	4/11/2017	10:41	SM 3113 B	4/20/2017	15:50	2.25	2.00	1	N	
LHAR-1-B-29A	N	P17-1739-37	PAS	NJDEP 15001	4/11/2017	10:44	SM 3113 B	4/20/2017	15:54	1.69	2.00	1	N	J
LHAR-1-B-30A	N	P17-1739-38	PAS	NJDEP 15001	4/11/2017	10:49	SM 3113 B	4/20/2017	16:05	0.573	2.00	1	N	J
LHAR-1-B-31A	N	P17-1739-39	PAS	NJDEP 15001	4/11/2017	10:53	SM 3113 B	4/20/2017	16:09	0.573	2.00	1	N	J
LHAR-1-B-32A	N	P17-1739-40	PAS	NJDEP 15001	4/11/2017	10:54	SM 3113 B	4/20/2017	16:13	0.853	2.00	1	N	J
LHAR-1-B-33A	N	P17-1739-41	PAS	NJDEP 15001	4/11/2017	10:55	SM 3113 B	4/20/2017	16:16	0.294	2.00	1	N	ND
LHAR-4-11-FBA	N	P17-1739-42	PAS	NJDEP 15001	4/11/2017	11:00	SM 3113 B	4/20/2017	16:24	-0.27	2.00	1	N	ND