

Report Date: August 17, 2022**Post Remediation Samples Collected:** August 10, 2022**Client:** Livingston Public School District**Name/Title:** Mr. James Perrette / Manager of Buildings & Grounds**Address:** 11 Foxcroft Drive, Livingston, NJ 07039**LEAD IN DRINKING WATER: POST REMEDIATION SAMPLING INTERIM REPORT****LOCATION:** Harrison Elementary School

148 N Livingston Ave

Livingston, NJ 07039

TYPE OF INSPECTION/TESTING: Two (2) Post Remediation Samples**DESCRIPTION, FINDINGS AND RECOMMENDATIONS:**

Following elevated results of two (2) drinking water outlets during initial sampling (above the New Jersey Department of Education (NJDOE) Action Level (AL) of 15 PPB) at Harrison Elementary School, the Livingston Public School District completed remediation by replacing the fixtures of both outlets.

The two (2) outlets re-sampled showed results below the NJDOE AL and additional remediation is not necessary at this time. These drinking water outlets can now be put back into service for District use.

Please post the attached laboratory results on the School/District website.

Respectfully Submitted,



Tara Ekiert, BS

Lead Industrial Hygienist

cc: Jane Boogaert and Brittney Christie (GSE)
Attachment – Laboratory results